

ADDENDUM NUMBER ONE
LINDSEY WWTP CLARIFIER IMPROVEMENTS
LINDSEY, OHIO
PROJECT NO. 10E08421
August 15, 2019

BID OPENING: Tuesday August 20, at 12:00 Noon local time at the offices of Feller,
Finch & Associates located at 1683 Woodlands Drive, Maumee, OH 43537.

PLAN SET

SHEET 5

The two (2) Proposed 2" Dia. PVC Electrical Conduits for the Pneumatic Controls may be installed above grade through the exterior south wall of the building before dropping down and going underground to the treatment cells. We do not require cutting through the interior floor slab of the existing building in order to install these.

BID DOCUMENTS

Section 00100 – INSTRUCTIONS TO BIDDERS

On page 00100-1 in Section 1.04 ENGINEER'S OPINION OF PROBABLE COST, change the amount of the estimate to \$320,000.00

Section 01450 – ALLOWANCES

On page 01450-1 in Section 1.02 LIST OF ALLOWANCES, add the following allowance Item:

“4. \$11,900 Freight to jobsite and Aero-mod equipment start-up, two (2) days.”

Change the ALLOWANCE TOTAL in Section 1.02 to read: “ALLOWANCE TOTAL = \$172,650.00”

Section 01500 – RELATED WORK AND PROJECT CONTROLS

On page 01500-14 Change PART FOUR – SPECIAL REQUIREMENTS Item 4.03 to read:

- 4.03 A. The project work described in 1.02.C.1. will be provided by the Owner.
- B. The project work described in 1.02.C.2. WILL NOT be provided by the Owner. The Contractor shall provide these services and the costs shall be included in the bid price per the pertinent project items.

Section 02510 – VIDEOTAPING

Replace Section 02510 with the attached Section 02510 VIDEOTAPING

END OF ADDENDUM #1

P:/Projects/10E08421/Project Specs/ADDENDUM NUMBER ONE_08.15.2019.wpd