

ADDENDUM NUMBER ONE
SOUTH SIDE STORM SEWER IMPROVEMENTS – PHASE I
VAN BUREN, OHIO
PROJECT NO. 10E08246
April 13, 2017

BID OPENING: Tuesday April 18, 2017 at 12:00 Noon local time at the Van Buren meeting room at 103 S. Main Street located in the rear of the Allen Township Fire Department in Van Buren, OH. The room is accessed through the rear (east side) of the building from the alley east of Main Street.

PLAN SET

Sheet 3

On the note for CATCH BASINS AND MANHOLES add the line: “All proposed catch basins and manholes shall be installed with KOR-N-SEAL Boot, PSX Fitting, or approved equal at all pipe openings.

Sheet 4

On the detail for TYPICAL CURB INLET OVER ODOT No. 3 MANHOLES add the note: “3. Curb Inlet Casting shall be East Jordan Iron Works 7000 Heavy Duty Frame with Type M1 Grate and Type T1 Back, or Neenah Equivalent.

On the detail for ODOT No. 3 MANHOLE WITH CATCH BASIN LID, make the following changes:

1. Change “O-Ring Joint ASTM C-443” to read “Butyl Sealant”
2. Delete the 10” dimension at the floor thickness. Floor thickness shall be per ODOT standards.

BID DOCUMENTS

Section 00300 – BID PROPOSAL FORM

On page 00300-8 Change the following quantities and add the attached revised sheet to the bid documents to replace the old sheet:

- Item 27 shall be changed to: “ODOT NO. 2-2B CATCH BASIN, 6 EACH”.

END OF ADDENDUM #1

P:/Projects/10E08246/Project Specs/ADDENDUM NUMBE ONE_04.13.2017.wpd

PROPOSAL TO THE VILLAGE OF VAN BUREN
VAN BUREN SOUTH SIDE STORM SEWER IMPROVEMENTS – PHASE I

BID SCHEDULE

| Bid Item | Item Description | Estm. Qty. | Unit | Unit Price Material | Unit Price Labor | Total Unit Price | Total Price |
|----------|--|------------|------|---------------------|------------------|------------------|-------------|
| 22 | ODOT NO. 3 MH W/CURB INLET, AS PER PLAN | 2 | EA | | | \$ | \$ |
| 23 | ODOT NO. 3 MH W/FLAT SLAB TOP, AS PER PLAN | 6 | EA | | | \$ | \$ |
| 24 | ODOT NO. 3 MH W/FLAT SLAB TOP AND CATCH BASIN LID, AS PER PLAN | 4 | EA | | | \$ | \$ |
| 25 | ODOT NO. 3 MH, AS PER PLAN | 3 | EA | | | \$ | \$ |
| 26 | ODOT NO. 3 MH W/CATCH BASIN LID, AS PER PLAN | 1 | EA | | | \$ | \$ |
| 27 | ODOT NO. 2-2B CATCH BASIN | 6 | EA | | | \$ | \$ |
| 28 | SUBGRADE IMPROVEMENT (CONTINGENCY) | 30 | CY | | | \$ | \$ |
| 29 | WATER MAIN RELOCATION | 1 | EA | | | \$ | \$ |
| 30 | TYPE K COPPER WATER SERVICE REPLACEMENT (CONTINGENCY) | 50 | FT | | | \$ | \$ |
| 31 | VIDEO RECORDING | 1 | LUMP | | | \$ | \$ |
| 32 | MAINTAINING TRAFFIC | 1 | LUMP | | | \$ | \$ |
| 33 | RESTORATION | 1 | LUMP | | | \$ | \$ |
| 34 | SOIL EROSION CONTROL | 1 | LUMP | | | \$ | \$ |
| | SUBTOTAL OF ALL BASE BID ITEMS | | | | | \$ | \$ |
| | ALTERNATE 1 | | | | | | |
| A-1 | RESURFACING – 441 ASPHALT CONCRETE SURFACE PG64-22, TYPE 1 (448) | 95 | CY | | | \$ | \$ |
| | TOTAL OF BASE BID PLUS ALTERNATE 1 ITEM | | | | | \$ | \$ |